

GOVERNMENT OF PUDUCHERRY
OFFICE OF THE DEPUTY DIRECTOR (IEC)
(STUDENT HEALTH OFFICE)

No.DD(IEC)/SHO/2023-24

PS-156

Pondicherry dt:

9 JAN 2024

SANITARY CERTIFICATE

The Director of Health Department, Puducherry is hereby grants sanitary certificate to the Institution as detailed below:

1)	Name and address of the school	:	PETIT SEMINAIRE HIGHER SECONDARY SCHOOL M.G. Road, Pondicherry – 605001
2)	Academic year	:	2023 – 2024
3)	Date of Inspection	:	30 – 11 – 2023
4)	Date of submission of Compliance Report	:	04 – 01 – 2024
5)	Date of issuance of Sanitary Certificate	:	09 – 01 – 2024
6)	Remarks (if any)		Nil

2.The management of the said school is informed that all the conditions as stipulated in the remarks and those prescribed in the Pondicherry School Education Rules, 1996 should be fulfilled failing which further continuance of renewal of sanitary certificate is liable to be rejected by this competent authority.

Sriamul
/Countersigned/
DIRECTOR
Directorate of Health and
Family Welfare Services
Puducherry.

Ke. Melananda
STUDENT HEALTH OFFICER
STUDENT HEALTH OFFICER
OFFICE OF THE DY. DIRECTOR (I.E.C)
DEPT. OF HEALTH & F.W. SERVICES
PUDUCHERRY.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0988
ULR-TC75802400000513F

Date: 10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0988	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Treated Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 1
Sample Received on	: 05.06.2024	Sampling Location	: Treated water, Higher Secondary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H*B	--	6.57	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	93.3	---	---
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	10.8	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	5.15	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	1.51	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	<0.50	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	<0.10	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	22.4	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	<5.00	200 Max	400 Max
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	<0.10	1.0 Max	1.5 Max

.....End of Report.....

L. Anita Ben
Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0988(Annexe)

Date:10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0988	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Treated Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 1
Sample Received on	: 05.06.2024	Sampling Location	: Treated water, Higher Secondary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	57.8	500 Max	2000 Max
Nitrate as NO ₃	APHA, 24th Edition, 2023, 4500-NO ₃ D	mg/L	3.18	45 Max	No Relaxation

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0989
ULR-TC758024000000514F

Date: 10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0989	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Ground Water	Sample Description	: Ground Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 2
Sample Received on	: 05.06.2024	Sampling Location	: Ground water, Higher Secondary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H ⁺ B	--	6.95	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	2860	---	---
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	279	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	645	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	137	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	73.9	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	0.43	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	771	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	159	200 Max	400 Max
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	0.19	1.0 Max	1.5 Max

.....End of Report.....

L. Anita Ben
Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0989(Annexe)

Date:10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS


Sample Code	: 2024/W-0989	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Ground Water	Sample Description	: Ground Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 2
Sample Received on	: 05.06.2024	Sampling Location	: Ground water, Higher Secondary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	1773	500 Max	2000 Max
Nitrate as NO ₃	APHA, 24th Edition, 2023, 4500-NO ₃ D	mg/L	13.6	45 Max	No Relaxation

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0990
ULR-TC758024000000515F

Date: 10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0990	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Treated Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 3
Sample Received on	: 05.06.2024	Sampling Location	: Treated water, Primary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

CHROMIUM REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H ⁺ B	--	6.68	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	62.0	---	---
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	4.13	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	6.34	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	1.31	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	0.75	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	<0.10	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	17.0	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	<5.00	200 Max	400 Max
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	<0.10	1.0 Max	1.5 Max

.....End of Report.....

L. Anita Ben
Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0990(Annexe)

Date:10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS


Sample Code	: 2024/W-0990	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Treated Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 3
Sample Received on	: 05.06.2024	Sampling Location	: Treated water, Primary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	38.4	500 Max	2000 Max
Nitrate as NO ₃	APHA, 24th Edition, 2023, 4500-NO ₃ D	mg/L	1.88	45 Max	No Relaxation

.....End of Report.....


Authorized Signatory
Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERRY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**



Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0991
ULR-TC758024000000516F

Date: 10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0991	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Ground Water	Sample Description	: Ground Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 4
Sample Received on	: 05.06.2024	Sampling Location	: Ground water, Primary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H*B	--	7.70	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	3060	---	---
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	268	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	596	200 Max	600 Max
Calcium as Ca	APHA, 23rd Edition, 2017, 3500-Ca B	mg/L	113	75 Max	200 Max
Magnesium as Mg	APHA, 23rd Edition, 2017, 3500-Mg B	mg/L	76.1	30 Max	100 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	0.30	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	806	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	183	200 Max	400 Max
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	0.63	1.0 Max	1.5 Max

.....End of Report.....

Copy submitted to:
The Executive Engineer,
PHD., PWD., Puducherry.

L. Anita Ben
Authorized Signatory
Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
PWD PONDICHERRY

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2024/W-0991(Annexe)

Date:10.06.2024

TEST REPORT- CHEMICAL

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry-605001.
Customer Reference : Letter dt:03.06.2024

Page 1 of 1

SAMPLE DETAILS

Sample Code	: 2024/W-0991	Information provided by the Customer	
Product Category	: Water	Sampled on	: 10.06.2024
Sample Name	: Ground Water	Sample Description	: Ground Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - 4
Sample Received on	: 05.06.2024	Sampling Location	: Ground water, Primary School Campus, Puducherry.
Test Started on	: 05.06.2024		
Test Completed on	: 10.06.2024		

TEST RESULTS

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	1897	500 Max	2000 Max
Nitrate as NO ₃	APHA, 24th Edition, 2023, 4500-NO ₃ D	mg/L	14.6	45 Max	No Relaxation

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No: TR/WTL/PHD/PDY/2024/B-0230

Date:07.06.2024

TEST REPORT

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355,Mahathma Gandhi Road, Puducherry.
Customer Reference : Letter dt:03.06.2024

SAMPLE DETAILS

Sample Code	: 2024/B-0230	Sampled by	Customer
Sample Name	: Water	Sampled on	05.06.2024
Sample Description	: Treated Water		
Temperature	: --	Sampling Location	Treated water, Higher Secondary School Campus, Puducherry.
Identificaiton by Customer	: Sample - 1	Sampling Procedure	--
Sample Condition	: Fit for analysis	Sample Received on	05.06.2024
Test Started on	: 05.06.2024	Test Completed on	07.06.2024

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No: TR/WTL/PHD/PDY/2024/B-0231

Date: 07.06.2024

TEST REPORT

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry.
Customer Reference : Letter dt: 03.06.2024

SAMPLE DETAILS


Sample Code	: 2024/B-0231	Sampled by	Customer
Sample Name	: Water	Sampled on	05.06.2024
Sample Description	: Ground Water		
Temperature	: --	Sampling Location	Ground water, Higher Secondary School Campus, Puducherry.
Identificaiton by Customer	: Sample - 2	Sampling Procedure	--
Sample Condition	: Fit for analysis	Sample Received on	05.06.2024
Test Started on	: 05.06.2024	Test Completed on	07.06.2024

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No: TR/WTL/PHD/PDY/2024/B-0232

Date:07.06.2024

TEST REPORT

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355,Mahathma Gandhi Road, Puducherry.
Customer Reference : Letter dt:03.06.2024

SAMPLE DETAILS


Sample Code	: 2024/B-0232	Sampled by	Customer
Sample Name	: Water	Sampled on	05.06.2024
Sample Description	: Treated Water		
Temperature	: --	Sampling Location	Treated water, Primary School Campus, Puducherry.
Identificaiton by Customer	: Sample - 3	Sampling Procedure	--
Sample Condition	: Fit for analysis	Sample Received on	05.06.2024
Test Started on	: 05.06.2024	Test Completed on	07.06.2024

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No: TR/WTL/PHD/PDY/2024/B-0233

Date: 07.06.2024

TEST REPORT

Customer Name & Address : The Principal,
Petit Seminaire Hr. Sec. School, No.355, Mahathma Gandhi Road, Puducherry.
Customer Reference : Letter dt: 03.06.2024

SAMPLE DETAILS

Sample Code	: 2024/B-0233	Sampled by	Customer
Sample Name	: Water	Sampled on	05.06.2024
Sample Description	: Treated Water		
Temperature	: --	Sampling Location	Ground water, Primary School Campus, Puducherry.
Identification by Customer	: Sample - 4	Sampling Procedure	--
Sample Condition	: Fit for analysis	Sample Received on	05.06.2024
Test Started on	: 05.06.2024	Test Completed on	07.06.2024

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vol3	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


Authorized Signatory
Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.